



D = PIPE DIAMETER.

- A. PUBLIC EASEMENT WIDTH SHALL BE DETERMINED BASED ON 1:1 SIDE SLOPE EXTENDING FROM THE FINISHED GRADE TO OUTSIDE EDGE OF PIPE (NOMINAL PIPE DIAMETER) ROUNDED UP TO THE NEAREST 1' INCREMENT.
- B. THIS EASEMENT SHALL EXTEND ALONG THE ENTIRE LENGTH OF THE SUBJECT PIPE AT LEAST ONE HALF THE DISTANCE OF EASEMENT PAST CENTER OF LAST MANHOLE.
- C. MIN. 20' UNLESS APPROVED BY PSA DIRECTOR.

REVISIONS				SANITARY SEWER EASEMENTS	DRAWING S-27
NO.	DATE				
ORIGINAL	12/01/06				